

Doepke Schaltgeräte GmbH — Postfach 10 01 68 — 26491 Norden

General information

Ihre Nachricht —

Ihr Zeichen —

Direktwahl —

Unser Zeichen —

Datum — 9.06.2023


Function test cycle of a residual current circuit breaker

Dear Sir or Madam,

The cycle for the functional testing of a residual current circuit breakers cannot be determined by the manufacturer. The appropriate test cycle depends on the type of installation, the environmental conditions and the installation regulations that apply to the electrical system.

We recommend a regular test of the residual current circuit breaker by pressing the test button. If used as intended, this is necessary at least once a year. The residual current circuit breaker has to trip during this testing.

i.A.



Best regards

Doepke Schaltgeräte GmbH
Heino Thoben-Mescher
Productmanagent

Doepke Schaltgeräte GmbH
Stellmacherstraße 11
26506 Norden

T — +49 4931 1806-0

F — +49 4931 1806-101

@ — info@doepke.de

www — doepke.de

Geschäftsführer — Andreas Müller

Registergericht — AG Aurich HRB 201934